



**Davie County Public Utilities  
Wastewater Collection  
Annual Performance Report for 2015**

**General Information:** County of Davie  
**Responsible Person:** Raymond Lambert

**Mailing address:** 298 E Depot St. Suite 200 Mocksville NC. 27028

**Phone Number:** 336-753-6090

**Permit Number:** WQCS00106

**Description of System:** Gravity, Force mains, Submersible  
Pump stations

**Description:**

Davie County operates a collection system that includes 11 pump stations: 12.1 miles of force main; 19.80 miles of gravity sewer 1.69 miles of 10" gravity sewer and 0.63 miles of 18" inch gravity sewer. Pumping an average daily flow of 267,000 gpd (Gallons Per day) through Yadkin River pump station to Forsyth County Utilities.

**Performance:**

Davie County over flows was caused by blockages from either grease or debris in the sewer lines. 2015 was the start of plan and design for the upgrade of the collections system in Eastern Davie County

**Notification:**


Each customer will receive a notice on the bi-monthly water bills notifying customers the report will be available online at [www.daviecountync.gov](http://www.daviecountync.gov), also available in our office located at 298 E Depot Street Mocksville NC. 27028. Davie County operates a government access channels on TWC channel 6 and Yadkin

Valley Telecom channel 25. This also provides great information that runs on a loop for FOG (Fats Oils and Grease).

We are excited to bring this 2014 system annual performance report to you and look forward to making 2015 an even better year in the performance of our system.

## Certification

Sign and date to certify that this report is accurate and complete:

Sign 

Date 3-7-2016