



# 2015 Performance Annual Report

## 1. General Information

**Facility Name:** Cooleemee WWTP  
**Responsible Person:** Timothy L. Smith  
**Mailing Address:** P.O. Box 768 Cooleemee, NC 27014  
**Phone:** 336-284-6680/336-753-6090  
**Permit Number(s):** NC0024872

**Description of Treatment:** Automatic Bar Screen, two 1.5 mg aeration basins, two clarifiers. One clarifier in use with one on standby. One 3mg basin and one 1.5mg basin, one 220,000 gallon aerobic digester, Chlorine Gas disinfection contact basin followed by a dechlorination basin using sulphur dioxide gas.

## II. Performance


Summary of Performance: (list all violation, corrective actions, improvements, etc.)  
No violations during 2015. Plant ran well, both clarifiers running improved plant process.  
Land Application events totaling 1,235,000 gallons or 138.53 Dry Tons.

## III. Notification

State how customers/users have been provided access to this report (mailing, posted, etc.)  
Each customer will receive a notice in the by-monthly water bills notifying customers the report will be available online at [www.daviecountync.gov](http://www.daviecountync.gov) also available in our office located at 298 E Depot Street Mocksville NC. 27028.

## IV. Certification

Sign and date to certify that the reports are accurate and complete:

  
Signature of Permitted

2-1-16  
Date

Mail original and two copies to:  
System Performance Annual Report