

DAVIE COUNTY NORTH CAROLINA

Davie County Public Utilities

336.753.6090

Davie County, in order to provide safe water to its customer has a backflow cross connection ordinance in accordance with state laws. This ordinance requires that anyone who meets a certain hazard criteria must have a backflow preventer installed and inspected by a certified backflow operator. Once the backflow assembly is installed it should be inspected and tested annually. Ownership, testing and maintenance of the backflow prevention assembly will be the responsibility of the customer. Each assembly required in this ordinance must be functioning properly at all times. Testing of backflow prevention assemblies shall be conducted by a certified tester (approved by Davie County Public Utilities Department) at the customer's expense. Tests shall be conducted upon installation and annually thereafter with a record of all testing and repairs retained by the customer for three years. A copy of the certified record for each test or repair must be sent to the Davie County Public Utilities Department by such customer or certified tester within thirty (30) days after the completion of each test or repair. Such records must be maintained on forms provided by the Davie County Public Utilities Department. Requirement that would necessitate a backflow device include but are not limited to;

- Lawn irrigation systems
- If the service line is connected through a well, or if there is a working well on the property.
- Any businesses that use or deal with hazardous chemicals such as; Hair salon, doctors' office, commercial and industrial businesses etc...

Specifications for approved backflow device and a list of approved backflow inspectors/installers, can be found on the official Davie County Website at www.daviecountync.gov

For any questions or concerns please contact:

Josh McChesney
Backflow/Cross Connection ORC
336-753-6096 Direct
336-753-6090 Office
joshmcchesney@daviecountync.gov



DAVIE COUNTY NORTH CAROLINA

Davie County Public Utilities
336.753.6090

